



# Port Hadlock UGA – Sewer Facility Plan

## Disinfection Evaluation

### Technical Perspectives

- ↑ Liquid hypochlorite **RECOMMENDED**
  - least expensive, effluent safe for reuse
- ↓ UV disinfection – more expensive, treatment with liquid hypochlorite would still be required for reuse

